

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE No. 53

Dated: 09/07/2026

It is certified that an inspection team headed by Dr. AJAY KUMAR MAURYA Bhadohi (Name of Officers with designation) from Public Health Department PHED inspected the Eva International School, Abholi Bhadohi on 09/07/2026 and on the basis of Water Test Report bearing of District Water Analysis Lab (PHED Lab) certified that the Eva International School has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 03/07/2031

E.M.O.
M.C.S. Distt. Hospital
Gyanpur-Bhadohi

Signature with Seal

Name :

Designation :

Dr. AJAY KUMAR MAURYA
.....
Dr. AJAY KUMAR MAURYA
MEDICAL OFFICER

Name & Address of the Office / Department : GYANPUR

To Manager Eva International School

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Test Report

District water Analysis Laboratory UP Jal Nigam(Rural)

MIG II 11&12 Jamunipur Colony

Sant Ravidas Nagar (Bhadohi)-221409



NABL T0826UP19019

Report No.	Test Report / Exe .Eng. Con .Divi. / Chemical Test /31/2026-27	Issue Date	19/09/2026	Page No	1 of 2	
Customer Details						
Office Name and Address	Eva International School Abholi, Bhadohi – 221404 (U.P.)					
Ref Letter No & Date	NA					
Basic details of sample						
District	Sant Ravidas Nagar Bhadohi	Block	Abholi			
Gram Panchyat	Abholi	Village	Abholi			
Habitation	-	Location	Abholi			
Water Source	Drinking Water	Sample Code	C/26/09/025			
Quantity of Sample	1.0 Ltr	Date Of S.C.	16/09/2026			
Receiving Date	16/09/2026	S. Collector	Sunil			
Sample Depositor	Sunil	Sampling Method Used	IS:17614:P-1:2021			
Analysis Start Date	17/09/2026	Analysis Completion Date	18/09/2026			
Environmental Condition						
Temperature	25 ± 3°C		Humidity	50 ± 15%		
Technical Data of Analysis						
S.No	Analyzed Parameters	Unit of Measurement	Observed value	Limits of IS: 10500-2012		Reference Method of Analysis
				Desirable Limit (Max)	Permissible Limit in the Absence of Alternate Source (Max)	
1.	pH	—	7.09	6.5-8.5	No relaxation	IS : 3025 (Part 11) - 2022
2.	Colour	Hazen	<5	5	15	APHA 24th Edition 2120 Colour Method B Platinum Cobalt Visual Comparison-2023
3.	Odour	—	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2022
4.	Taste	—	Agreeable	Agreeable	Agreeable	IS : 3025 (Part 8) - 2023
5.	Turbidity	NTU	1.24	01	05	IS : 3025 (Part 10) - 2024
6.	Total Dissolve Solids	mg/l	136.0	500	2000	IS : 3025 (Part 16) - 2023
7.	Total Alkalinity (as CaCO ₃)	mg/l	40.0	200	600	IS 3025 (Part 23) : 2023
8.	Total Hardness(as CaCO ₃)	mg/l	96.0	200	600	IS 3025 (Part 21) : 2023
9.	Calcium as Ca	mg/l	30.4	75	200	IS 3025 (Part 40) : 2024
10.	Magnesium as Mg	mg/l	4.87	30	100	IS 3025 (Part 46) : 2023
11.	Sulphate (as SO ₄)	mg/l	29.33	200	400	APHA 24th Edition – 4500-SO ₄ Method E (Turbidity Method, 2023)
12.	Nitrate(as NO ₃)	mg/l	1.33	45	No relaxation	APHA 24th Edition – 4500-NO ₃ Method B (UV Screening Method ,2023)

13.	Iron(as Fe)	mg/l	0.31	1.0	No relaxation	APHA 24th Edition – 3500-Fe Method B (Phenanthroline ,2023)
14.	Fluoride	mg/l	0.02	1.0	1.50	APHA 24th Edition -4500-F Method C (Electrode Method) 2023
15.	Chloride (as Cl)	(mg/l)	25.98	250.0	1000.0	IS 3025 (Part 32) : 2023

*BDL-Below Detection Limit.

- Note-
1. This certificate refers only to the particular samples submitted for testing.
 2. This certificate shall not be reproduced ,except in full, unless written permission for the publication of an approved abstract .
 3. The test results reported in this certificate are valid at the time of and under the started conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports

Prepared by:
Manish Kumar Yadav
(Deputy Technical Manager)

Manish Kumar



Laboratory contact details :-Name- Mahendra Pal
Mo. No. 9919087307
Email ID:-mahendrapal4491@gmail.com

*** END OF THE REPORT***



Test Report

District water Analysis Laboratory UP Jal Nigam(Rural)

MIG II 11&12 Jamunipur Colony

Sant Ravidas Nagar (Bhadohi)-221409

Report No.	Test Report / Exe .Eng. Con .Divi. / Microbial Test 127/2026-27	Issue Date	19/09/2026	Page No	01
------------	--	------------	------------	---------	----

Customer Details

Office Name and Address	Eva International School Abholi, Bhadohi – 221404 (U.P.)
Ref Letter No & Date	NA

Basic details of sample

District	Sant Ravidas Nagar Bhadohi	Block	Abholi
Gram Panchyat	Abholi	Village	Abholi
Habitation	-	Location	Abholi
Water Source	Drinking Water	Sample Code	B/26/09/025
Quality of Sample	1.0 Ltr	Date Of S.C.	16/09/2026
Receiving Date	16/09/2026	S. Collector	Sunil
Sample Depositor	Sunil	Sampling Method Used	IS:1622-2003 IS:17614:P-1:2021
Analysis Start Date	17/09/2026	Analysis Completion Date	18/09/2026

Environmental Condition

Temperature	25 ± 3°C	Humidity	50 ± 15%
-------------	----------	----------	----------

Technical Data of Analysis

S. No	Parameters		Observed value	Unit	Limits of IS: 10500-2012		
					Desirable Limit (Max)	Permissible Limit in the Absence of Alternate Source (Max)	Reference Method of Analysis
1.	Total coli form	E. coli	NIL	CFU/100ML	NIL	NIL	IS 15185:2016
		T. Coliform	NIL				

UNC = Uncountable

Tested by:

Manish Kumar Yadav

Manish Kumar

Authorized signatory

Mahendra Pal

Laboratory contact details: - Name- Mahendra Pal
Mo. No. 9919087307
Email ID:-mahendrapal4491@gmail.com

*** END OF THE REPORT***

